

LORRIN W. PANG, M.D., M.P.H.
DISTRICT HEALTH OFFICER

STATE OF HAWAII DEPARTMENT OF HEALTH MAUI DISTRICT HEALTH OFFICE

54 HIGH STREET WAILUKU, HAWAII 96793

April 11, 2013

Mr. Daniel E. Orodenker Executive Officer Department of Business Economic Development & Tourism State of Hawaii P. O. Box 2359 Honolulu, Hawaii 96804-2359

Dear Mr. Orodenker:

Subject:

Maui Research & Technology Park Master Plan Update, Final EIS

Thank you for the opportunity to review this project. We have the following comments to offer:

- 1. National Pollutant Discharge Elimination System (NPDES) permit coverage maybe required for this project. The Clean Water Branch should be contacted at 808 586-4309.
- 2. The noise created during the construction phase of the project may exceed the maximum allowable levels as set forth in Hawaii Administrative Rules (HAR), Chapter 11-46, "Community Noise Control." A noise permit may be required and should be obtained before the commencement of work. The Indoor & Radiological Health Branch should be contacted at 808 586-4700.
- 3. HAR, Chapter 11-46 sets maximum allowable sound levels from stationary equipment such as compressors and HVAC equipment. The attenuation of noise from these sources may depend on the location and placement of these types of equipment. This should be taken into consideration during the planning, design and construction of the building and installation of these types of equipment.

It is strongly recommended that the Standard Comments found at the Department's website: http://hawaii.gov/health/environmental/env-planning/landuse.html be reviewed, and any comments specifically applicable to this project should be adhered to.

Mr. Daniel E. Orodenker April 11, 2013 Page 2

Should you have any questions, please call me at 808 984-8230 or E-mail me at patricia.kitkowski@doh.hawaii.gov.

Sincerely,

Patti Kitkowski

District Environmental Health Program Chief

c OEQC EPO